

## NERC Standards Review Subcommittee

---

**Subject:** NSRS Weekly Meeting  
**Start:** Wednesday 07/07/2010 9:00 AM CDT  
**End:** Wednesday 07/07/2010 11:00 AM CDT

### Conference Call Capabilities:

**Conference Phone Number:** 800.503.2899

**Access Code:** 8551728

### WebEx:

[https://core2.callinfo.com/interface/guest.jsp?host=globalcrossing&mmid=0&javaForwarded=true&javatested=true&jvm=1.6.0\\_13&signed=false](https://core2.callinfo.com/interface/guest.jsp?host=globalcrossing&mmid=0&javaForwarded=true&javatested=true&jvm=1.6.0_13&signed=false)

### New Business:

Meeting minutes are in green highlighted text.

### Ballots:

- o **Project 2010-12: Order 693 Directives**, the opportunity to vote ends 07/13/10 (NERC) and **07/07/10 (NSRS)**. Dan was asked to vote according to the comment form and keep the VSL and VRF voting options blank. Actual comments would be submitted through the comment period.
- 1. **Project 2007-01: Underfrequency Load Shedding**, the opportunity to vote ends TBA (NERC) and **07/07/10 (NSRS)**. Dan was asked to vote "negative" on this ballot. (8 members voted "negative" and 1 member voted to abstain).
- o **Project 2007-17: Protection System Maintenance & Testing**, the opportunity to vote ends TBA (NERC) and **07/07/10 (NSRS)**.
  - For the project 2007-17's ("Protection System Maintenance & Testing") new definition of Protection Systems, the NSRS would like to vote "negative" on this definition (6 members voted "negative", 2 members voted "affirmative", and 1 member voted to abstain) and they would like to submit a comment, "The MRO's NERC Standards Review Subcommittee believes the proposed protection system definition is unclear specifically as it relates to dc station supply. We would like more clarity as to what is included in the dc station supply. We believe battery chargers should not be included in the definition; if the Standard Drafting Team revises the definition we would ask that Table 1 be adjusted, accordingly."
  - For the project 2007-17's New Standard PRC-005, the NSRS would like to vote "negative" on this standard (8 members voted "negative" and 1 member voted to abstain.) and they would like to submit a comment with the vote: "The MRO's NERC Standards Review Subcommittee believes the proposed implementation plan for R1 is unreasonably short. It proposes that: "Entities shall be 100% compliant on the first day of the first calendar quarter three months following applicable regulatory approvals, or in those jurisdictions where no regulatory approval is required, on the first day of the first calendar quarter six months following Board of Trustees adoption." We believe the implementation periods should be expanded to twice what was proposed in the implementation plan due to the sheer volume of equipment that will need to meet compliance. Thus, we propose an alternate implementation plan for requirement R1, "Entities shall be 100% compliant on the first day of the first calendar quarter six months following applicable regulatory approvals, or in those jurisdictions where no regulatory approval is required, on the first day of the first calendar quarter twelve months following Board of Trustees adoption."

**Note:** The proposed definition for Protection System was not submitted with the vote since three versions of the proposed protection system definition were received and at least one member expressed support for one of these versions.

#### Posted for Comments:

- **Reliability Standards Development plan: 2010-2012**, POC - ?, Comments are due **07/08/10**. **Comment form** **No comments were received.**
- **Project 2010-12: Order 693 Directives**, POC- Joe DePoorter, Comments are due **07/13/10**. **Comments were submitted.**
- **Project 2007-18: Reliability-based Control**, POC – Jodi Jenson, Comments are due **07/15/10**. **Comments to be distributed to the group mid-morning on Friday (07/09/10). NSRS will be asked to comment/vote on these comments by noon on Monday (07/12/10). Comments will be submitted in the afternoon Monday.**
- **Project 2007-01: Underfrequency Load Shedding**, POC – Chuck Lawrence, Comments are due **07/16/10**. **A meeting was arranged to discuss and finalize these comments. It's scheduled for Monday (07/12/10 9-11 AM CDT). After the call, MAPP sent their comments to the NSRS.**
- **Project 2007-17: Protection System Maintenance & Testing**, POC – Carol Gerou, Comments are due **07/16/10**. **No Comments were received.**
- **Project 2007-07: Vegetation Management**, POC – Joe Knight, Comments are due 07/17/10. **During the call, ATC sent their comments to the NSRS.**

#### Ballot Pools:

- **Project 2007-07: Vegetation Management**, the opportunity to join the ballot pool ends 07/07/10.

**Nominations: N/A**

**Old Business: N/A**

#### Industry Information:

- **NERC Webinar – “Protection System Coordination”**. Start time 12 PM EST. [Register](#). **Dates and Topics:**
  - July 15, 2010 – Differential, Reverse Power, and Negative Sequence
- **NOPR (RM09-25-000 date 06/17/2010)(FERC Citation 131FERC61,254)**. System Personnel Training Reliability Standards. (See Attached.) POC - Joe DePoorter. Comments due in August, 2010.

#### General Information:

To view current NERC Standards under development activity follow this link:

[http://www.nerc.com/filez/standards/Reliability\\_Standards\\_Under\\_Development.html](http://www.nerc.com/filez/standards/Reliability_Standards_Under_Development.html)

To view information on the NSRS (calendar, comments posted to NERC, agenda and meeting information please check the MRO website:

[http://www.midwestreliability.org/STA\\_nerc\\_stand\\_review\\_subcommittee.html](http://www.midwestreliability.org/STA_nerc_stand_review_subcommittee.html)