

**The MRO NSRS submits the following comments on the CAN-0018 (“FAC-008-1, R1.2.1, Terminal Equipment”):**

1. Within this CAN there are several devices that are described as “Terminal Equipment” along with a final catch-all which states, “Any piece of equipment that is in series with the circuit and that could become a limiting element”. Please remove Potential devices unless examples can given of what these devices actually are. Please add Circuit Switches. Please remove either “Circuit Breaker” or “Breakers”. The NSRS believe that these are one in the same.

2. Please note that if this CAN is approved as is describes what Terminal Equipment is. The Reliability Standards Development Process should be used to define this term.