

The Midwest Reliability Organization's NERC Standards Review Forum would like to submit the following comments for CAN-0029:

The Background section of CAN-0029 is inaccurate with the use of the statement, "within or across their entire organization and not just limited to the area effect by the current location of the misoperation". M1, M2, and M3 of PRC-004-1 do not use this statement, the Measurements clearly state "according to the Regional Reliability Organization procedures developed for PRC-003, R1".

Recommend that CAN-0029 be updated to accurately state what is in the Measurements of PRC-004-1

Informational links:

<http://www.nerc.com/files/DRAFT%20CAN%200029%20Misoperations.pdf>

[http://www.nerc.com/files/Consistent Protection System Misoperation Reporting Webinar 2-10-2011.pdf](http://www.nerc.com/files/Consistent%20Protection%20System%20Misoperation%20Reporting%20Webinar%202-10-2011.pdf)

We are concerned that the Reliability Objective is pointing to the BPS instead of the BES. Since the BPS includes more facilities/equipment than BES, and BES is what NERC enforces requirements to, we suggest BPS be replaced with BES in the Reliability Objective statement.