

PRC-502-MRO-02 – Power System Stabilizer Requirement and Small Signal Stability Assessment

Unofficial Comment Form

Please use the Reliability Standards Voting Process (RSVP) application to submit all comments.

Comments are due by 11:59 pm CST **April 14, 2010**. If you have any questions, please contact the Standards Process Manager at spm@midwestreliability.org.

Background Information

Comments on the third draft of the PRC-502-MRO-02 (“Power System Stabilizer (PSS) Requirement and Small Signal Stability Assessment”) Regional Reliability Standard were received from industry through December 2, 2009. The Clarification Drafting Team sought and received feedback to 1 question, and the team appreciates the industry’s participation. A brief noteworthy change from draft 3 to draft 4 is that R8 and R10 have been modified to require more extensive testing for PSS installations required as part of a corrective plan (R1/R5) and non-intrusive verification testing every 10 years for fundamentally all operational power system stabilizers.

Given this change, is this standard ready for ballot? If not, what changes would you suggest?

Yes

No

Comments: